



Product Service

Attestation of Conformity

No. N8 13 02 69801 004

Holder of Certificate: DASSTECH CO., LTD.

109, Yangcheongsongdae-gil, Ochang-eup
Cheongwon-gun, Chungbuk 363-883
REPUBLIC OF KOREA

**Product: Power supply
(PV(Photovoltaic) INVERTER)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0139582

Date, 2013-02-14

(Ian Young-Yul Hwang)



CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8 13 02 69801 004**Model(s):** **DSP-33100K, DSP-3375K****Parameters:**

Input Ratings	
MPTT Range:	350-820 VDC
Max. Voltage:	1000 VDC
Max. Current:	330 A(DSP-33100K), 236 A(DSP-3375K)
Output Ratings	
Output voltage:	380 VAC
Output power:	105 kW(DSP-33100K), 75 kW(DSP-3375K)
Max. Output current:	175 A(DSP-33100K), 125 A(DSP-3375K)
Output frequency:	60 Hz
Protection class:	I
Degree of protection:	IP20

Tested
according to:

EN 50178:1997